



Certificate of Compliance

This certificate is issued for the following:

PIPE HANGER COMPONENTS FOR AUTOMATIC SPRINKLER SYSTEMS

<i>Product Designation</i>	<i>Hanger Rod Size, in. NC</i>	<i>Component Description</i>	<i>For Nominal Pipe Sizes, in.</i>
TKLS Ø 11 Steel Bite	M10	Beam Clamp	3/4 through 4
TKLS Ø 13 Steel Bite	M12	Beam Clamp	5, 6, 8
TKLS Ø 17 Steel Bite	M16	Beam Clamp	10

Prepared for:

fischerwerke GmbH and Co KG
Weinhalde 14-18, D-72178
Waldachtal, Germany

FM Approvals Class: 1951

Approval Identification: 0003052618

Approval Granted: May 27, 2014

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', is written over a horizontal line.

Richard B. Dunne
Group Manager –Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group